

1.1 **Board of High Pressure Piping Systems**

1.2 **Proposed Permanent Rules Relating to High Pressure Piping**

1.3 **5230.0005 DEFINITIONS.**

1.4 Subpart 1. **Scope.** The terms used in parts 5230.0005 to 5230.5920 and Minnesota
1.5 Statutes, sections 326B.91 and 326B.921 to 326B.925, have the meanings given them in
1.6 this part.

1.7 Subp. 2. **Administrative authority.** "Administrative authority" means the inspection
1.8 agency authorized to inspect high pressure piping under Minnesota Statutes, sections
1.9 326B.90 and 326B.92, subdivision 2.

1.10 Subp. 3. **Ammonia piping system.** "Ammonia piping system" means a piping
1.11 system conveying ammonia that is used for refrigeration.

1.12 Subp. 4. **ASME.** "ASME" means the American Society of Mechanical Engineers.

1.13 Subp. 5. **Bioprocess piping.** "Bioprocess piping" means piping and equipment used
1.14 for conveying living organisms for medical, research, or pharmaceutical purposes, but
1.15 does not include piping used to make bio food products or treat waste.

1.16 Subp. 6. **Bioprocess piping system.** "Bioprocess piping system" means a piping
1.17 system for bioprocess piping.

1.18 Subp. 7. **Contractor.** "Contractor" means an entity with a valid high pressure piping
1.19 business license, as described in Minnesota Statutes, section 326B.921, subdivision 2.

1.20 Subp. 8. **Department.** "Department" means the Department of Labor and Industry.

1.21 Subp. 9. **Direct supervision.** "Direct supervision," with respect to direct supervision
1.22 of an unlicensed individual by a licensed contracting high pressure pipefitter or a licensed
1.23 journeyman high pressure pipefitter, means that:

2.1 A. at all times while the unlicensed individual is performing high pressure
2.2 piping work, the supervising pipefitter is present at the location where the unlicensed
2.3 individual is working;

2.4 B. the supervising pipefitter is physically present and immediately available to
2.5 the unlicensed individual at all times for assistance and direction;

2.6 C. electronic supervision does not meet the requirements of item B;

2.7 D. the supervising pipefitter reviews the high pressure piping work performed
2.8 by the unlicensed individual before the high pressure piping system is operated or placed
2.9 in service; and

2.10 E. the supervising pipefitter is able to and does determine that all high pressure
2.11 piping work performed by the unlicensed individual is performed in compliance with
2.12 this chapter.

2.13 Subp. 10. **High pressure piping system.** "High pressure piping system" means:

2.14 A. a steam or heating media piping system;

2.15 B. an ammonia piping system; or

2.16 C. a bioprocess piping system.

2.17 Subp. 11. **High pressure piping work.** "High pressure piping work" means
2.18 activities for which a contracting or journeyman high pressure pipefitter license is required
2.19 under Minnesota Statutes, section 326B.921, subdivision 1.

2.20 Subp. 12. **Other medium used for heating.** "Other medium used for heating" means
2.21 hot oil or other liquid that transfers heat without a phase change. Other medium used for
2.22 heating does not include products within refinery and chemical process complexes that
2.23 exchange heat with other product streams as part of the core process.

3.1 Subp. 13. **Pipefitting laws.** "Pipefitting laws" means this chapter, chapter 5231, and
3.2 Minnesota Statutes, sections 326B.90 to 326B.925.

3.3 Subp. 14. **Piping system.** "Piping system" means the method of conveying liquid,
3.4 vapor, steam, water, ammonia, or other medium from one point to another and includes
3.5 all component parts, accessories, apparatus, equipment, or appurtenances necessary for
3.6 proper and safe operation according to this chapter. Piping system includes pipes, flanges,
3.7 bolting, gaskets, valves, fittings, the pressure-containing elements or portions of the
3.8 system, piping and equipment supporting elements, hangers, or structural attachments.

3.9 Subp. 15. **Power piping system.** "Power piping system" means high pressure
3.10 piping system.

3.11 Subp. 16. **Repairs on an existing installation.** "Repairs on an existing installation"
3.12 means the in-kind replacement of:

3.13 A. **manufactured threaded nipples up to six inches in length; or**

3.14 B. **flanged or threaded valves, strainers, traps, or fittings, or gaskets for these**
3.15 items.

3.16 Subp. 17. **Steam or heating media piping.** "Steam or heating media piping" means
3.17 any system of piping hot water or other medium used for heating that exceeds 30 p.s.i.
3.18 gauge and 250 degrees Fahrenheit, or any system of piping high pressure steam in excess
3.19 of 15 p.s.i. gauge.

3.20 Subp. 18. **Steam or heating media piping system.** "Steam or heating media piping
3.21 system" means a piping system for steam or heating media piping.

3.22 **5230.0035 REGISTRATION OF UNLICENSED INDIVIDUAL.**

3.23 Subpart 1. **Scope.** Subparts 2 to 5 shall not apply to any individual employed in
3.24 the trade of pipefitting under an apprenticeship agreement approved by the department
3.25 under part 5200.0300.

4.1 Subp. 2. **Unlicensed individual registration requirement.** No unlicensed
4.2 individual under the age of 18 shall perform high pressure piping work. An individual
4.3 who is 18 years of age or older must be registered with the department if the individual
4.4 does not hold a contracting or journeyman high pressure pipefitter license and if the
4.5 individual performs high pressure piping work.

4.6 Subp. 3. **Information required to be provided by applicant on initial and renewal**
4.7 **registration application.** An applicant for registration must provide the following
4.8 information on the initial application form and each renewal application form provided
4.9 by the department:

- 4.10 A. **complete name;**
4.11 B. **date of birth;**
4.12 C. **Social Security number;**
4.13 D. **home address;**
4.14 E. **telephone number; and**
4.15 F. **date of application.**

4.16 Subp. 4. **Change in information.** A registered unlicensed individual is responsible
4.17 for keeping current the information provided to the department under subpart 3. A
4.18 registered unlicensed individual must notify the department within 30 days of a change
4.19 in any of the information in the most recent application submitted by the individual to
4.20 the department under subpart 3.

4.21 Subp. 5. **Registration card.** The unlicensed individual shall carry the registration
4.22 card issued by the department at all times when the unlicensed individual is performing
4.23 high pressure piping work. The unlicensed individual shall present the registration card to
4.24 the administrative authority upon request.

4.25 **5230.0045 COMPETENCY LICENSING REQUIREMENT.**

5.1 Subpart 1. **License required.** All licensed contracting high pressure pipefitters and
5.2 licensed journeyman high pressure pipefitters shall carry their license on their person
5.3 at all times while performing high pressure piping work, and shall produce the license
5.4 upon request by the administrative authority.

5.5 Subp. 2. **Construction.** Construction of high pressure piping for installation in
5.6 Minnesota, regardless of where constructed, shall meet the requirements of the pipefitting
5.7 laws.

5.8 Subp. 3. **Remedies required for licensing violations.** The remedies described in
5.9 this subpart are in addition to any other remedies provided by law. The enforcement of the
5.10 remedies described in this subpart shall not preclude the use of any other enforcement
5.11 provision in law for violations of the licensing requirements in the pipefitting laws, such
5.12 as any provision allowing the commissioner to assess penalties or take disciplinary action.

5.13 A. **Construction.** As used in this item, the term "unauthorized piping" means
5.14 any high pressure piping constructed by a person who does not hold the license required
5.15 under the pipefitting laws. If any unauthorized piping is installed as part of a high pressure
5.16 piping system in Minnesota, then:

5.17 (1) the unauthorized piping must be removed; and

5.18 (2) the high pressure piping system that includes the unauthorized piping
5.19 cannot be placed in service unless and until the unauthorized piping is replaced with
5.20 high pressure piping constructed by a person who holds the license required under the
5.21 pipefitting laws.

5.22 B. **Installation.** As used in this item, the term "unauthorized installation" means
5.23 any high pressure piping installed by a person who does not hold the license required
5.24 under the pipefitting laws. If there is an unauthorized installation in a high pressure piping
5.25 system, then:

6.1 (1) the unauthorized installation must be removed; and

6.2 (2) the high pressure piping system that includes the unauthorized
6.3 installation cannot be placed in service unless and until the unauthorized installation is
6.4 replaced with high pressure piping installed by a person who holds the license required
6.5 under the pipefitting laws.

6.6 **5230.0060 COMPETENCY LICENSE APPLICATIONS FOR REGISTRATION.**

6.7 Subpart 1. ~~Contractor and journeymen~~ Contracting high pressure pipefitter and
6.8 journeyman high pressure pipefitter licenses. Application for a ~~contractor's contracting~~
6.9 high pressure pipefitter's license and registration or a journeyman high pressure pipefitter's
6.10 license shall be made to the secretary of the ~~Division of Pipefitting Standards at least 30~~
6.11 days prior to the next scheduled examination department on blanks forms provided for
6.12 that purpose by the ~~division~~ department. Application for a ~~journeyman's contracting high~~
6.13 pressure pipefitter's license or a journeyman high pressure pipefitter's license shall be filed
6.14 with the ~~division~~ department at least ~~ten~~ 15 days ~~prior to the next~~ before examination. The
6.15 ~~council may waive the rule applying to journeyman examinations in emergency cases. If~~
6.16 ~~the statements made by the applicant in said application form indicate that the applicant~~
6.17 ~~possesses the necessary qualifications to take an examination, the secretary shall notify~~
6.18 ~~him or her of the time and place of examination.~~ An application for a contracting high
6.19 pressure pipefitter's or journeyman high pressure pipefitter's license shall be valid for 12
6.20 months from the date the application is received by the department.

6.21 If, on examination, the applicant ~~fully~~ qualifies, the ~~council~~ department shall ~~so~~
6.22 ~~certify to the department, which shall thereupon~~ issue to the applicant a license as a
6.23 contracting high pressure pipefitter or journeyman high pressure pipefitter, as the case
6.24 may be, for the remainder of the calendar year. If ~~an~~ the applicant fails to ~~qualify at an~~
6.25 ~~examination, the council shall so certify to the secretary, who shall notify the applicant of~~
6.26 ~~failure to pass~~ the examination, the applicant cannot retake the examination until at least

one month after the date of the failed examination. Before retaking the examination, the applicant must submit a new application and examination fee.

Subp. 2. [Repealed, L 2007 c 140 art 13 s 3]

5230.0070 CONTRACTING HIGH PRESSURE PIPEFITTER QUALIFICATIONS.

~~Applicants~~ An applicant for a license as a contracting high pressure pipefitter shall:

A. be at least 21 years of age;

B. ~~possess sufficient education~~ be able to read and comprehend blueprints, specifications, and terms of contracts, and to compute the cost of installing high pressure piping and equipment;

C. have worked at the trade of high pressure pipefitting for at least five years;

D. be examined as to their knowledge of high pressure pipefitting, the requirements of the pipefitting laws ~~and minimum standards~~ for the installation of high pressure piping in ~~the state of~~ Minnesota, their ability to lay out a plan of high pressure piping, and their knowledge of the physics and mechanics applicable to high pressure piping;

E. generally demonstrate to the ~~council~~ department their fitness to properly, intelligently, and lawfully carry on the business of a contracting ~~and employing~~ high pressure pipefitter in ~~the state of~~ Minnesota;

~~F. be of good moral character;~~

~~G.~~ F. pay an examination fee; and

~~H.~~ G. pass the required examination ~~by~~ with a weighted score of at least 70 ~~percent~~ out of 100.

5230.0080 JOURNEYMAN HIGH PRESSURE PIPEFITTER QUALIFICATIONS.

~~Applicants~~ An applicant for license as a journeyman high pressure pipefitter shall:

- 8.1 A. be at least 20 years of age;
- 8.2 B. ~~possess sufficient education~~ be able to read and comprehend blueprints and
- 8.3 specifications for the installation of high pressure piping;
- 8.4 C. ~~be of good moral character;~~
- 8.5 ~~D. C. for at least four years,~~ have been a registered ~~pipefitter trainee or~~
- 8.6 ~~journeyman pipefitter for at least four years~~ unlicensed individual or pipefitter apprentice,
- 8.7 or have worked in the trade of high pressure pipefitting;
- 8.8 ~~E. D.~~ pay an examination fee; and
- 8.9 ~~F. E.~~ pass the required examination ~~by~~ with a weighted score of at least 70
- 8.10 percent out of 100.

8.11 **5230.0090 EXAMINATION OF APPLICANTS FOR COMPETENCY LICENSES.**

8.12 Subpart 1. **Contents.** Examinations shall consist of written ~~or oral~~ questions and

8.13 drawings of plans and sketches, except that when an applicant ~~is disabled for~~ has a

8.14 disability and is unable to provide a written examination, the examination may be entirely

8.15 oral. All questions and sketches shall pertain to practical experience and knowledge of

8.16 pipefitting and be standard, but may be changed from time to time.

8.17 Subp. 2. [See repealer.]

8.18 Subp. 3. **Test results.** Applicants shall be notified of the outcome of their

8.19 examination after their ~~papers have~~ examination has been ~~graded~~ scored. The notice to

8.20 those who failed to pass shall inform them ~~of their privilege of reexamination without the~~

8.21 ~~payment of another fee at the next examination held of which they are notified~~ that: (1)

8.22 they cannot retake the examination until at least one month after the date of the failed

8.23 examination; and (2) they will need to submit a new application and examination fee

8.24 before retaking the examination.

9.1 **5230.0095 HIGH PRESSURE PIPING BUSINESS LICENSES.**

9.2 **Subpart 1. High pressure piping business license required.** An individual, person,
9.3 partnership, firm, corporation, or association must obtain or use a business with a high
9.4 pressure piping business license before obtaining a permit for high pressure piping work.

9.5 **Subp. 2. High pressure pipefitting business license procedure.** To obtain a high
9.6 pressure pipefitting business license, as required by Minnesota Statutes, section 326B.921,
9.7 subdivision 2, an applicant must submit a form approved by the department and signed
9.8 by the applicant. The application shall include the applicant's certification that the
9.9 applicant has:

9.10 **A. workers' compensation insurance required by law or that the applicant is**
9.11 **exempt;**

9.12 **B. public liability insurance as required by Minnesota Statutes, section**
9.13 **326B.921, subdivision 6; and**

9.14 **C. a high pressure pipefitting business license performance bond that meets the**
9.15 **requirements of Minnesota Statutes, section 326B.921, subdivision 5.**

9.16 **With the application, the applicant shall submit copies of the applicant's workers'**
9.17 **compensation insurance certificate, if not exempt; the applicant's public liability insurance**
9.18 **certificate; the applicant's high pressure pipefitting business license performance bond;**
9.19 **and a check for the amount of the fee required by Minnesota Statutes, section 326B.921,**
9.20 **subdivision 7. The term of the high pressure pipefitting business license shall be a calendar**
9.21 **year or the balance of the calendar year after application. High pressure pipefitting**
9.22 **business licenses must be renewed annually on a calendar-year basis.**

9.23 **Subp. 3. Affiliation with licensed high pressure contracting pipefitter.**

9.24 **A. If a high pressure pipefitting business licensee is an individual, then that**
9.25 **individual must be a licensed contracting high pressure pipefitter. If a high pressure**

pipefitting business licensee is not an individual, then the business licensee must have a licensed contracting high pressure pipefitter who works full time for the business licensee and who is affiliated with the business licensee in one of the following capacities:

(1) as an employee;

(2) as the proprietor, if the business licensee is a sole proprietorship;

(3) as a partner, if the business licensee is a partnership;

(4) as an officer, if the business licensee is a corporation; or

(5) as a member, if the business licensee is a limited liability company.

B. If at any time the high pressure pipefitting business licensee no longer meets the requirements of item A, then the business licensee must notify the department within five business days after the last day that the business licensee met the requirements of item A. If the business licensee fails to meet the requirements of item A for 60 or more consecutive calendar days, then the high pressure pipefitting business license shall lapse.

5230.0120 RIGHTS OF LICENSED CONTRACTING HIGH PRESSURE PIPEFITTER.

A contracting high pressure pipefitter's license shall entitle the pipefitter to work as a journeyman high pressure pipefitter under rules applicable to journeyman high pressure pipefitters, but a journeyman high pressure pipefitter's license shall not entitle the holder thereof to ~~do business work~~ as a contracting high pressure pipefitter.

5230.0180 SURRENDER OF LICENSE UPON REVOCATION.

~~When a pipefitter's any high pressure piping license is revoked, the licensee shall at once surrender the certificate and identification card to the secretary of the Division of Pipefitting Standards~~ immediately surrender the license to the department.

5230.0190 DUPLICATE LICENSES.

11.1 Duplicate licenses and identification cards may be issued by the ~~secretary~~ department
11.2 upon ~~proof~~ certification by the license holder that the original is lost or mutilated.

11.3 **5230.0220 BIOPROCESS PIPING.**

11.4 Subpart 1. ASME BPE. All bioprocess piping must meet the requirements of
11.5 ASME BPE. For purposes of this chapter, "ASME BPE" means the 2005 edition of the
11.6 Bioprocessing Equipment Standard adopted and published by ASME, Three Park Avenue,
11.7 New York, New York 10016. ASME BPE is incorporated by reference and made part of
11.8 the code for high pressure piping systems. ASME BPE is not subject to frequent change
11.9 and a copy of ASME BPE is available in the office of the commissioner of labor and
11.10 industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint
11.11 Paul, Minnesota 55155.

11.12 Subp. 2. Examination of welded pipe joints. All welds on bioprocess piping
11.13 systems must comply with the visual examination acceptance standards in sections MJ-6.3
11.14 to MJ-6.4 of ASME BPE. When nondestructive examination other than visual examination
11.15 is required by job specification or by the administrative authority, the welds must comply
11.16 with the acceptance standards in sections MJ-6.3 to MJ-6.4 of ASME BPE for each type
11.17 of nondestructive examination required. All costs of nondestructive testing shall be paid
11.18 by the installing contractor. The contractor shall provide a copy of all examination results
11.19 to the administrative authority upon request.

11.20 **CODE FOR STEAM OR HEATING MEDIA PIPING SYSTEMS**

11.21 **5230.0250 ~~PURPOSE~~ MINIMUM STANDARDS.**

11.22 Parts 5230.0250 to 5230.0335 form the code for steam or heating media piping
11.23 systems. This code prescribes minimum requirements for design, manufacture, test, and
11.24 installation of ~~power~~ steam or heating media piping systems, ~~as defined below, for steam~~
11.25 ~~generating plants, central heating plants, industrial plants, and district heating.~~

12.1 **5230.0260 SCOPE.**

12.2 ~~"Power piping systems" shall be understood to include all steam piping and the~~
12.3 ~~component parts such as pipe, flanges, bolting, gaskets, valves, and fittings, within or~~
12.4 ~~forming a part of the above-mentioned plants, including central and district heating steam~~
12.5 ~~or hot water distribution piping away from the plant, building heating piping when the~~
12.6 ~~pressure exceeds 15 psi gage for steam, or 30 psi gage for hot water and a temperature~~
12.7 ~~exceeding 250 degrees Fahrenheit, whether the piping is installed underground or~~
12.8 ~~elsewhere.~~

12.9 Valves, fittings, and piping for boilers, as prescribed in the ASME Code for Power
12.10 Boilers, are within the scope for this code but provisions of the ASME Code for Power
12.11 Boilers shall govern where they exceed corresponding requirements of this code. For
12.12 purposes of this chapter, "ASME Code for Power Boilers" means the 2007 edition of the
12.13 ASME Boiler and Pressure Vessel Code, section I, as adopted and published by ASME,
12.14 Three Park Avenue, New York, New York 10016. The ASME Code for Power Boilers
12.15 is incorporated by reference in the code for steam or heating media piping systems. The
12.16 ASME Code for Power Boilers is not subject to frequent change, and a copy is available in
12.17 the office of the commissioner of labor and industry and at the State Law Library, 25 Rev.
12.18 Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

12.19 Economizers, heaters, tanks, and other pressure vessels are outside the scope of this
12.20 code, but connecting piping shall conform to the requirements herein specified.

12.21 **5230.0265 ADOPTION OF ASME B31.1 BY REFERENCE.**

12.22 For purposes of this chapter, "ASME B31.1" means the 2007 revision of the standard
12.23 for power piping, as approved and published by ASME, Three Park Avenue, New York,
12.24 New York 10016. ASME B31.1 is incorporated by reference and made part of the code for
12.25 steam or heating media piping systems, except as amended in this chapter. Portions of this
12.26 chapter reproduce text from ASME B31.1. ASME B31.1 is not subject to frequent change
12.27 and a copy of ASME B31.1 is available in the office of the commissioner of labor and

13.1 industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint
13.2 Paul, Minnesota 55155. ASME B31.1 is copyright by ASME. All rights reserved.

13.3 **5230.0275 CHAPTER I, SCOPE AND DEFINITIONS.**

13.4 **Section 100.1.2.** The first paragraph of part (A) of ASME B31.1, section 100.1.2
13.5 is amended to read as follows:

13.6 (A) This code covers boiler external piping as defined below for power boilers and
13.7 high temperature, high pressure water boilers in which: steam or vapor is generated at a
13.8 pressure of more than 15 p.s.i. gauge; and high temperature water or other medium used
13.9 for heating is generated at pressures exceeding 30 p.s.i. gauge and temperatures exceeding
13.10 250 degrees Fahrenheit (120 degrees Celsius).

13.11 **5230.0285 CHAPTER II, DESIGN.**

13.12 Subpart 1. **Parts 1 and 2.** Notwithstanding anything to the contrary in ASME
13.13 B31.1, the following portions of chapter II of ASME B31.1 are recommended rather
13.14 than mandatory: Part 1, Conditions and Criteria; and Part 2, Pressure Design of Piping
13.15 Components. The department shall not enforce compliance with Part 1 or Part 2 of
13.16 chapter II of ASME B31.1

13.17 Subp. 2. **Section 122.5.1.** ASME B31.1, section 122.5.1 is amended by adding
13.18 the following language at the end:

13.19 It is mandatory that a pressure gauge be installed on the low-pressure side of a reducing
13.20 valve. Where two or more reducing valves are installed in series, a pressure gauge shall be
13.21 installed on the low-pressure side of each pressure-reducing valve.

13.22 Subp. 3. **Section 122.7.** ASME B31.1, section 122.7 and all subsections are deleted.

13.23 Subp. 4. **Section 122.8.** ASME B31.1, section 122.8 and all subsections are deleted.

13.24 Subp. 5. **Section 122.9.** ASME B31.1, section 122.9 is deleted.

14.1 Subp. 6. Section 122.11.2. ASME B31.1, section 122.11.2 is amended by adding
14.2 the following language at the end:

14.3 The discharge of a high pressure trap shall not empty into a low-pressure receiver unless
14.4 first run through a flash tank or there is an ample sized vent so a trap failure could not
14.5 increase the pressure in low-pressure receiver tank.

14.6 **5230.0295 CHAPTER III, MATERIALS.**

14.7 Section 124 is amended by adding a subsection as follows:

14.8 **124.11. Furnace Butt Welded Pipe**

14.9 The use of furnace butt welded pipe is prohibited on steam or heating media piping
14.10 systems.

14.11 **5230.0305 CHAPTER VI, INSPECTION, EXAMINATION, AND TESTING.**

14.12 Section 136. ASME B31.1, section 136 and all subsections are deleted.

14.13 **5230.0315 CHAPTER VII, OPERATION AND MAINTENANCE.**

14.14 Chapter VII of ASME B31.1 is deleted in its entirety.

14.15 **5230.0325 APPENDICES.**

14.16 Notwithstanding anything to the contrary in ASME B31.1, the following "Mandatory
14.17 Appendices" in ASME B31.1 are recommended rather than mandatory: A, D, G, H, and
14.18 J. The department shall not enforce compliance with "Mandatory Appendices" A, D, G,
14.19 H, or J of ASME B31.1.

14.20 **5230.0335 EXAMINATION OF WELDED PIPE JOINTS.**

14.21 All welds on steam or heating media piping systems must comply with the
14.22 visual examination acceptance standards in section 136.4.2 of ASME B31.1. When
14.23 nondestructive examination other than visual examination is required by job specification
14.24 or by the administrative authority, the welds must comply with the acceptance standards in
14.25 sections 136.4.3 to 136.4.6 of ASME B31.1 for each type of nondestructive examination

15.1 required. All costs of nondestructive testing shall be paid by the installing contractor. The
15.2 contractor shall provide a copy of all examination results to the administrative authority
15.3 upon request.

15.4 **CODE FOR AMMONIA REFRIGERATION SYSTEMS**

15.5 **5230.5000 MINIMUM STANDARDS.**

15.6 Parts 5230.5000 to ~~5230.6200~~ 5230.5915 form the code for ammonia refrigeration
15.7 systems and applies to ammonia piping systems used for closed circuit refrigeration
15.8 systems. Parts 5230.5000 to ~~5230.6200~~ 5230.5915 are minimum standards ~~and are not~~
15.9 ~~intended to be used as or considered as a system design manual except as otherwise~~
15.10 ~~specified. If a system has any component designed for temperatures below minus 20~~
15.11 ~~degrees Fahrenheit (minus 28.9 degrees centigrade), then the entire system, including~~
15.12 ~~components, must meet the test requirements of the American Society of Mechanical~~
15.13 ~~Engineers, American National Standards Institute, B31.5 refrigerating systems for~~
15.14 ~~operating at temperatures below minus 20 degrees Fahrenheit (minus 28.9 degrees~~
15.15 ~~centigrade).~~

15.16 **5230.5001 INCORPORATIONS BY REFERENCE.**

15.17 Subpart 1. ANSI/IIAR 2. For purposes of this chapter, "ANSI/IIAR 2" means the
15.18 2008 revision of the standard for Equipment, Design, and Installation of Closed-Circuit
15.19 Ammonia Mechanical Refrigerating Systems, as approved by the American National
15.20 Standards Institute and as published by the International Institute of Ammonia
15.21 Refrigeration, 1110 North Glebe Road, Suite 250, Arlington, Virginia 22201. ANSI/IIAR 2
15.22 is incorporated by reference and made part of the code for ammonia refrigeration systems,
15.23 except as amended in this chapter. Portions of this chapter reproduce text from ANSI/IIAR
15.24 2. ANSI/IIAR 2 is not subject to frequent change and a copy of ANSI/IIAR 2 is available
15.25 in the office of the commissioner of labor and industry and at the State Law Library, 25

16.1 Rev. Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155. ANSI/IIAR 2 is
16.2 copyrighted by the International Institute of Ammonia Refrigeration. All rights reserved.

16.3 Subp. 2. ASME B31.5. For purposes of this chapter, "ASME B31.5" means the 2006
16.4 revision of the standard for ammonia refrigeration piping as approved and published by
16.5 ASME, Three Park Avenue, New York, New York 10016. ASME B31.5 is incorporated
16.6 by reference and made part of the code for ammonia refrigeration piping. ASME B31.5 is
16.7 not subject to frequent change and a copy of ASME B31.5 is available in the office of
16.8 the commissioner of labor and industry and at the State Law Library, 25 Rev. Dr. Martin
16.9 Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

16.10 **5230.5003 SECTION 3, DEFINITIONS.**

16.11 ANSI/IIAR 2, Section 3, is amended by adding the following definitions:

16.12 **brine:** Any liquid used for the transmission of heat without a change in its state.

16.13 **jurisdictional authority:** Administrative authority, as defined in Minnesota Rules, part
16.14 5230.0005, subpart 2.

16.15 **liquid line:** The parts of the ammonia refrigerating system, at any pressure, intended
16.16 to be wholly filled with liquid refrigerant.

16.17 **5230.5005 SECTION 10, PIPING.**

16.18 Subpart 1. Section 10.2.1.5. ANSI/IIAR 2, section 10.2.1.5, is amended by adding
16.19 a subsection as follows:

16.20 **10.2.1.5.1. Application of materials.**

16.21 a. Carbon steel liquid lines must utilize A106 seamless pipe or
16.22 A333 seamless pipe.

16.23 b. Piping material used in the discharge line of a pressure relief
16.24 device, when discharging to atmosphere, Type F buttweld pipe
16.25 is allowed.

17.1 c. Mill test reports must be provided for the inspector at the
17.2 inspector's discretion to verify heat numbers on the pipe and to
17.3 verify compliance with this part.

17.4 Subp. 2. Section 10.2.2.1. ANSI/IIAR 2, section 10.2.2.1, is amended to read as
17.5 follows:

17.6 10.2.2.1. Carbon steel, welded.
17.7 a. 1-1/2 inch and smaller - schedule 80.
17.8 b. 2 inch through 10 inch - schedule 40.
17.9 c. 12 inch and larger - standard weight.

17.10 Subp. 3. Section 10.2.2.3. ANSI/IIAR 2, section 10.2.2.3, is amended to read as
17.11 follows:

17.12 10.2.2.3. Stainless steel, welded.
17.13 a. 3/4 inch through 6 inch - schedule 40.
17.14 b. 8 inch and larger - schedule 10.

17.15 Subp. 4. Section 10.3.1.3. ANSI/IIAR 2, section 10.3.1.3, is amended to read as
17.16 follows:

17.17 10.3.1.3. Operating speed of control valve actuators shall be considered in
17.18 the system design. Quarter turn valves (ball valves, butterfly valves, etc.)
17.19 must utilize an actuator that restricts the time from fully open to fully closed,
17.20 both directions, to at a minimum of 60 seconds.

17.21 **5230.5007 SECTION 11, OVERPRESSURE PROTECTION DEVICES.**

17.22 Subpart 1. Section 11.1.5. ANSI/IIAR 2, section 11.1.5, is amended to read as
17.23 follows:

17.24 11.1.5. Relief valves shall not be located in refrigerated spaces unless precautions
17.25 are taken to prevent moisture migration into the valve body or relief valve vent
17.26 line. A drip pocket the size of the discharge pipe and at least 24 inches in length

18.1 must be installed below a vertical riser in the discharge pipe and must be fitted
18.2 with a drain plug or valve.

18.3 Subp. 2. Section 11.1.6.2. ANSI/IIAR 2, section 11.1.6.2, is amended by adding the
18.4 following paragraph at the end:

18.5 Rupture discs may only be used when installed in series with a pressure
18.6 relief valve.

18.7 Subp. 3. Section 11.2.5. ANSI/IIAR 2, section 11.2.5, is amended to read as follows:

18.8 11.2.5. Pressure vessels of 10 ft³ [0.3 m³] or more internal gross volume shall
18.9 be protected by one or more dual pressure relief device(s). Dual pressure relief
18.10 valves shall be installed with a three-way valve to allow testing or repair. When
18.11 dual relief valves are used, each valve must meet the requirements of section
18.12 11.2.7. When multiple dual relief valve assemblies are used,

18.13 a. the sum of the capacities of the pressure relief devices actively protecting
18.14 the vessel must equal or exceed the requirements of section 11.2.7, and

18.15 b. the capacity of any dual relief assembly whose manifold valve is set to
18.16 a position other than fully seated (one side open and one side closed) shall
18.17 be counted to be zero.

18.18 **5230.5009 SECTION 15, TESTING AND CHARGING.**

18.19 ANSI/IIAR 2, section 15.1.7, is amended by adding a subsection to read as follows:

18.20 15.1.7.6. Declaration. A dated declaration of test shall be provided for all
18.21 systems. The declaration shall give the name of the refrigerant and the field
18.22 test pressure applied to the high side and the low side of the system. The
18.23 declaration of test shall be signed by the installer or, if permitted by the
18.24 administrative authority, by the owner's representative. If a representative of
18.25 the administrative authority is present at the test, that representative shall
18.26 also sign the declaration.

19.1 **5230.5915 PIPING JOINTS.**

19.2 Subpart 1. **Design standards.** Piping joints must be designed for ammonia service.
19.3 Joints must be designed for the pressure temperature and mechanical strength requirements
19.4 of ammonia service and items A to E.

19.5 A. One and one-quarter inch and smaller joints may be threaded or welded.
19.6 Threaded pipe must be American Society for Testing and Materials schedule 80 seamless.
19.7 Threaded fittings must be 2,000 pounds per square inch rating. Threaded fittings must
19.8 be forged steel.

19.9 B. Joints one and one-half inch and larger must be welded. Fittings must match
19.10 pipe schedule and material. Welded pipe one and one-half inch and smaller must be
19.11 jointed with the use of socket weld fittings of at least ~~3,000~~ 2,000 pounds per square inch
19.12 ratings or butt weld fittings of the same wall thickness and material as the pipe. Socket
19.13 weld fittings must be forged steel.

19.14 C. Flanges must be a tongue and groove type, or raised face type, rated ~~at least~~
19.15 ~~300 pounds per square inch~~ and designed for ammonia service and system pressure.

19.16 D. Gaskets must be designed for ammonia service and system pressure.

19.17 E. Unions must be at least ~~3,000~~ 2,000 pounds per square inch forged steel
19.18 ground joint unions, and must be used only for three quarters inch and smaller pipe;
19.19 ~~and must be socket weld.~~

19.20 Subp. 2. **Branch, run-outs, laterals, and saddles.** When joining carbon steel to
19.21 carbon steel material, if the main piping is two inches and smaller, or the branch or run-out
19.22 is two inches and smaller, branch or lateral connections must be forged steel TEE fitting,
19.23 forged steel WELD-O-LETTM or THREAD-O-LETTM, or engineering equivalent of
19.24 at least 3,000 pounds per square inch rating. Engineering equivalency must be based

20.1 on proper documentation signed by a registered professional engineer. When joining
20.2 materials other than carbon steel to carbon steel, ASME standard B31.5 must be followed.

20.3 Where the main piping exceeds two inches, branch or lateral connections
20.4 must be made by forged steel TEE fitting, be forged steel WELD-O-LETTM, or
20.5 THREAD-O-LETTM of at least ~~3,000~~ 2,000 pounds per square inch rating; or in cases
20.6 where the branch exceeds two inches (further providing that a branch lateral or saddle is
20.7 two pipe sizes smaller than the main piping it is connected to) the connection may be made
20.8 by the use of a saddle or lateral connection that complies with the requirements of this part.

20.9 Branches or ~~runouts~~ run-outs the same size as the main must be connected using
20.10 forged steel TEE fittings.

20.11 Welding of saddles and laterals must comply with the provisions of ASME standard
20.12 B31.5 ~~and result in proper fusion through the weld and must be subjected to nondestructive~~
20.13 ~~testing including radiography at the discretion of the administrative authority.~~

20.14 ~~The costs of nondestructive testing for labor and materials and all testing media must~~
20.15 ~~be at the expense of the installing contractor.~~

20.16 Subp. 3. [See repealer.]

20.17 Subp. 4. [See repealer.]

20.18 Subp. 5. **Components.** The assembly of the various components, whether done in
20.19 a shop or as a field erection, must be done so that the completely erected piping and
20.20 equipment conform with the requirements of this chapter.

20.21 Subp. 6. Examination of welded pipe joints. All welds on ammonia piping systems
20.22 must comply with the visual examination acceptance standards in section 527.3.2 of
20.23 ASME B31.5. When nondestructive examination other than visual examination is
20.24 required by job specification or by the administrative authority, the welds must comply
20.25 with the acceptance standards in section 536.6.3 of ASME B31.5 for each type of
20.26 nondestructive examination required. All costs of nondestructive testing shall be paid by

21.1 the installing contractor. The contractor shall provide a copy of all examination results to
21.2 the administrative authority upon request.

21.3 **5230.5920 QUALIFICATION OF WELDING PROCEDURES, WELDERS, AND**
21.4 **WELDING OPERATORS.**

21.5 Subpart 1. **Scope.** This part applies to welding that is part of any high pressure
21.6 piping work, except where the welding is regulated by other codes or Minnesota state
21.7 regulatory bodies, such as the Power Boiler and Unfired Pressure Vessel sections of the
21.8 ASME Boiler and Pressure Vessel Code.

21.9 Subp. 2. **Incorporation by reference.** For purposes of this chapter, "ASME section
21.10 IX" means the 2007 revision of section IX of the Boiler and Pressure Vessel Code, as
21.11 approved and published by ASME, Three Park Avenue, New York, New York 10016.
21.12 ASME section IX is incorporated by reference and made a part of this chapter. ASME
21.13 section IX is not subject to frequent change. A copy of ASME section IX is available in
21.14 the office of the commissioner of labor and industry and at the State Law Library, 25 Rev.
21.15 Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

21.16 Subp. 3. **Welding qualifications.** Standard qualifications for welding procedures,
21.17 welders, and welding operators made according to ASME section IX qualify for work
21.18 under this part.

21.19 Subp. 4. **Retest and renewal of welder qualification.** Welders and welding
21.20 operators must meet the standard requirements for initial welder qualification, welder
21.21 continuity requirements, and retest and renewal requirements, as set forth in ASME
21.22 section IX.

21.23 Subp. 5. **Weld procedure and qualification requirements.** No welding may be
21.24 performed on high pressure piping systems without a welding procedure specification and
21.25 an associated procedure qualification record. Welding performed on high pressure piping

22.1 systems must be performed using only welders properly qualified according to the welding
22.2 procedure. All welding procedures must meet the requirements of ASME section IX.

22.3 Subp. 6. **Evaluation standards.** The welding procedure specification and procedure
22.4 qualification record must be objectively evaluated by and acceptable to the administrative
22.5 authority.

22.6 Subp. 7. **Documentation required.** Welding performed on high pressure piping
22.7 systems must be supported by the mandatory documents of the welding procedure
22.8 specification, welding procedure qualification, and procedure qualification record. These
22.9 documents must be available at the work site.

22.10 Subp. 8. **Welder identification and log requirement.** A welder qualified for a
22.11 project must be assigned an identification symbol unique to that welder. Each weld must
22.12 be stamped or marked with the welder's identification symbol. A welding log must be
22.13 maintained as set forth in ASME section IX.

22.14 Subp. 9. **Contractor responsibility.** The contractor is responsible for establishing
22.15 and retaining the needed documents to conform to the requirements of this part.

22.16 **REPEALER.** Minnesota Rules, parts 5230.0050; 5230.0090, subpart 2; 5230.0100,
22.17 subparts 2, 3a, and 6; 5230.0115; 5230.0130; 5230.0140; 5230.0150; 5230.0160;
22.18 5230.0170; 5230.0200; 5230.0210; 5230.0270; 5230.0280; 5230.0290; 5230.0300;
22.19 5230.0310; 5230.0320; 5230.0330; 5230.0340; 5230.0350; 5230.0360; 5230.0370;
22.20 5230.0380; 5230.0390; 5230.0400; 5230.0410; 5230.0420; 5230.0430; 5230.0440;
22.21 5230.0450; 5230.0460; 5230.0470; 5230.0480; 5230.0490; 5230.0500; 5230.0510;
22.22 5230.0520; 5230.0550; 5230.0560; 5230.0570; 5230.0580; 5230.0590; 5230.0600;
22.23 5230.0610; 5230.0650; 5230.0660; 5230.0670; 5230.0680; 5230.0690; 5230.0750;
22.24 5230.0760; 5230.0770; 5230.0780; 5230.0790; 5230.0850; 5230.0860; 5230.0870;
22.25 5230.0880; 5230.0890; 5230.0950; 5230.0960; 5230.0970; 5230.0980; 5230.0990;
22.26 5230.1000; 5230.1010; 5230.1020; 5230.1030; 5230.1040; 5230.1050; 5230.1060;

- 23.1 5230.1070; 5230.1080; 5230.1090; 5230.1100; 5230.1110; 5230.1120; 5230.1130;
23.2 5230.1200; 5230.1210; 5230.1220; 5230.1230; 5230.1240; 5230.1250; 5230.1260;
23.3 5230.1270; 5230.5010; 5230.5015; 5230.5020; 5230.5025; 5230.5250; 5230.5300;
23.4 5230.5350; 5230.5400; 5230.5605; 5230.5610; 5230.5615; 5230.5620; 5230.5625;
23.5 5230.5630; 5230.5635; 5230.5640; 5230.5645; 5230.5650; 5230.5655; 5230.5660;
23.6 5230.5665; 5230.5675; 5230.5680; 5230.5690; 5230.5700; 5230.5705; 5230.5710;
23.7 5230.5820; 5230.5825; 5230.5915, subparts 3 and 4; 5230.5925; 5230.5930; 5230.5935;
23.8 5230.5940; 5230.5945; 5230.5950; 5230.5960; 5230.6100; 5230.6110; 5230.6115;
23.9 5230.6120; 5230.6125; 5230.6130; and 5230.6200, are repealed.
- 23.10 **EFFECTIVE DATE.** Minnesota Rules, part 5230.0005, subpart 6, "Repairs on an
23.11 existing installation," is effective August 1, 2010. All other amendments are effective 45
23.12 days after publication of the notice of adoption in the State Register.

INCORPORATIONS BY REFERENCE:

Part 5230.0220, subpart 1: "ASME BPE" means the 2005 edition of the Bioprocessing Equipment Standard adopted and published by ASME, Three Park Avenue, New York, New York 10016. ASME BPE is not subject to frequent change and a copy of ASME BPE is available in the office of the commissioner of labor and industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

Part 5230.0260: "ASME Code for Power Boilers" means the 2007 edition of the ASME Boiler and Pressure Vessel Code, section I, as adopted and published by ASME, Three Park Avenue, New York, New York 10016. The ASME Code for Power Boilers is not subject to frequent change, and a copy is available in the office of the commissioner of labor and industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

Part 5230.0265: "ASME B31.1" means the 2007 revision of the standard for power piping, as approved and published by ASME, Three Park Avenue, New York, New York 10016. ASME B31.1 is not subject to frequent change and a copy of ASME B31.1 is available in the office of the commissioner of labor and industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155. ASME B31.1 is copyright by ASME. All rights reserved.

Part 5230.5001, subpart 1: "ANSI/IIAR 2" means the 2008 revision of the standard for Equipment, Design, and Installation of Closed-Circuit Ammonia Mechanical Refrigerating Systems, as approved by the American National Standards Institute and as published by the International Institute of Ammonia Refrigeration, 1110 North Glebe Road, Suite 250, Arlington, Virginia 22201. ANSI/IIAR 2 is not subject to frequent change and a copy of ANSI/IIAR 2 is available in the office of the commissioner of labor and industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155. ANSI/IIAR 2 is copyrighted by the International Institute of Ammonia Refrigeration. All rights reserved.

Part 5230.5001, subp. 2: "ASME B31.5" means the 2006 revision of the standard for ammonia refrigeration piping as approved and published by ASME, Three Park Avenue, New York, New York 10016. ASME B31.5 is not subject to frequent change and a copy of ASME B31.5 is available in the office of the commissioner of labor and industry and at the State Law Library, 25 Rev. Dr. Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

Part 5230.5920, subp. 2: "ASME section IX" means the 2007 revision of section IX of the Boiler and Pressure Vessel Code, as approved and published by ASME, Three Park Avenue, New York, New York 10016. ASME section IX is incorporated by reference and made a part of this chapter. ASME section IX is not subject to frequent change. A copy of ASME section IX is available in

the office of the commissioner of labor and industry and at the State Law Library, 25 Rev. Dr.
Martin Luther King Jr. Blvd., Saint Paul, Minnesota 55155.

Office of the Revisor of Statutes

Administrative Rules



TITLE: Proposed Permanent Rules Relating to High Pressure Piping

AGENCY: Board of High Pressure Piping Systems

MINNESOTA RULES: Chapter 5230

INCORPORATIONS BY REFERENCE: [See attached pages]

The attached rules are approved for
publication in the State Register

A handwritten signature in dark ink, reading "Craig E. Lindeke".

Craig E Lindeke
Senior Assistant Revisor